

Sri Lanka CERT (Pvt.) Ltd

ADDENDUM NO 01 - TO THE BIDDING DOCUMENT

FOR THE

Procurement of Production Data Center Co-Location for NCSOC

INVITATION FOR BIDS No: CERT/GOSL/SER/NCB/2023/03

September 2022

ADDENDUM NO 01 - TO THE BIDDING DOCUMENT

INVITATION FOR BIDS No: **CERT/GOSL/SER/NCB/2023/03**

This Addendum to the Bidding Document of above procurement incorporates following amendments. All bidders shall comply with these amendments in addition to the clarifications issued. All the changes are highlighted for the easy reference.

Amendments

| | <i>Section/Page number</i> | <i>Original Requirement</i> | <i>Revised or additional requirement</i> |
|----|--|---|---|
| 01 | Security against earthquake risk. Page. 35 / 2.1 | PML less than 10 - 20% | Point removed |
| 02 | Physical Partition (Cage) Page 36 / 2.4 | Physically separated partition with secure metal wire cage fences or any other option. This cage must be dedicated to Sri Lanka CERT. | Not mandatory |
| 03 | Ability to provide 240 V / 2* 8A /2*16A /2*32A/2*64 Page 38 / 4.8 | (active/active by independent distribution paths, load balanced), and each rack should be capable of supplying up to 240 V /2* 8 A /2*16A /2*32A/2*64 | (active/active by independent distribution paths, load balanced), and each rack should be capable of supplying up to 240 V /2* 8 A /2*16A /2*32A/2*64 |
| 04 | Server Room temperature Page 39 / 5.3 | 16 Celsius to 22 Celsius | 25 Celsius or below |
| 05 | Physical layout Page 41 / 8.1.a | Space for 2*42U equipment rack | 02 racks. Diagram has been removed. |
| 06 | Physical layout Page 41 / 8.1.c | Provide minimum 2.5 feet space from front and back side of the racks for easy access and maintenance. | It is required to fulfill according to the tier 3 standard. |

Price Schedule

| 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 |
|--------------|---|------|--|---|---|-------------|--|---|
| Item No | Description of Goods | unit | Unit price Excluding VAT LKR | Total Price Excluding VAT LKR | Discounted Total Price (If any) Excluding VAT LKR | Other Taxes | VAT | Total Price Including VAT LKR |
| | | | <i>[insert price per unit]</i> | <i>[Col (3)*(4)]</i> | <i>[insert total cost for total quantity for inland transportation and other services required]</i> | | <i>[insert total VAT for total quantity]</i> | <i>[(6)+(7)+(8)]</i> |
| 01 | Monthly cost for space for 42U rack (Excluding power consumption) | | | | | | | |
| 02 | Cost for power consumption per ampere. | 10 | | | | | | |
| Total | | | | | | | | |

Note 1: The power consumption will be considered as 10 Amperes for evaluation purposes. Payment shall be done on a usage basis.

Note 2: Bidder should have meet me room to bring any type of ISP (ILL, P2P, VPN last mile) links from different Internet Service providers (example: Sri Lanka Telecom, Dialog, Lankacom) & should extend same to Sri Lanka CERT cage / racks without any active device involvement of colocation service provider & any additional cost to Sri Lanka CERT or to the connectivity provider.